

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-0273:101

Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: United Air, PO Box 40913, Nashville TN 37204
Contact: *Jon Newnam (615) 256-3500

DESIGN: Models CFD-1, CFD-2 and CFD-R fire dampers with or without suffix A. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, fire resistive rating and UL label.

APPROVAL: Listed as fire-rated dampers. Types CFD-R and CFD-1 may be installed in up to a 3-hour fire-rated ceiling/floor or ceiling/roof assembly; Type CFD-2 may be installed in up to a 1-hour fire-rated ceiling/floor or ceiling/roof assembly.

NOTE: Leakage rating not evaluated. Refer to CSFM Listing Category 3230 for listed leakage dampers.

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager